Electric Outages Lewes BPW

Month	Date	Circuit	Customers Interrupted	Duration	Cause	Percent System Reliability
January 2018	1/12/2018	3	32	180	Equipment Damage	99.78726%
-	1/20/2018	2	5	30	Squirrel	
	1/20/2018	1	1	30	Squirrel	



